

CBS ArcSafe®


Distance Is Safety®

A Group CBS Company

Installation and Operation

RSA-117B

For Westinghouse
Load Break Switch



Distance is Safety®

WHAT STANDS
BETWEEN YOU AND
ARC-FLASH DANGER?

**WE
DO.**

2616 Sirius Road | Denton, TX 76208 | (877) 4-SAFETY | www.cbsarcsafe.com

Rev. 5/1/2015

More Products by CBS ArcSafe®

RRS-1 – Universal Remote Racking System (Rotary)

The CBS ArcSafe® RRS-1 is a universal remote racking system capable of remotely installing and removing rotary style draw out circuit breakers without requiring any modification to the existing switchgear. Operation of the simple to use RRS-1 is quite intuitive and requires only minimal setup. When used properly, the RRS-1 allows technicians to remain outside of the arc flash boundary during the potentially dangerous racking operation.

RRS-2 – Universal Remote Racking System (Non-Rotary)

The CBS ArcSafe® RRS-2 is a universal remote racking system capable of remotely installing and removing non-rotary style draw out circuit breakers without requiring any modification to the existing switchgear. Operation of the simple to use RRS-2 is quite intuitive and requires only minimal setup. When used properly, the RRS-2 allows technicians to remain outside of the arc flash boundary during the potentially hazardous racking operation.

RRS-3 – Application Specific Remote Racking System (Rotary And Non-Rotary)

The CBS ArcSafe® RRS-3 product line is made up of various application specific remote breaker racking devices. Each standalone system allows service personnel to remotely install and remove a particular type of circuit breaker safely while stationed safely outside of the arc flash boundary during the potentially dangerous operation. The lightweight and compact design of the RRS-3 systems makes them ideal for hard to access areas where space is at a premium.

RRS-4 – PLC Based Universal Remote Racking System (Rotary)

The CBS ArcSafe® RRS-4 universal remote racking system is an updated PLC based version of the best selling RRS-1. The dual mode, source programmable, PLC based control system offers two different operating modes to choose from based on user preference or the application. The RRS-4 is capable of remotely installing and removing rotary style draw out circuit breakers without requiring any modification to the existing switchgear, allowing users to remain outside of the arc flash boundary during the potentially hazardous racking operation.

RSA – Remote Switch Actuator

The CBS ArcSafe® Remote Switch Actuator (RSA) product line is made up of various application specific remote operating devices. These products allow service personnel to remotely perform all aspects of an operation for a particular type of electrical equipment from outside the arc flash boundary – reducing or eliminating the possibility of serious injury or death resulting from an arc flash.

RSO – Remote Switch Operator

During a remote operation, the CBS ArcSafe® RSO functions as both the power supply and user interface for the device being remotely operated by the user. When paired with an applicable CBS ArcSafe® device, this portable standalone system allows service personnel to remotely perform a racking or switching procedure from outside the arc flash boundary – reducing or eliminating the possibility of injury or death resulting from an arc flash

Published and distributed by:
CBS ArcSafe®
2616 Sirius Road
Denton, Texas 76208

A division of:
GroupCBS, Inc.®
P.O. Box 1557
Gainesville, Texas 76241

Copyright CBS ArcSafe® 2013

Printed in the United States of America
Reproduction, adaptation, or translation without prior written permission is prohibited except as is allowed by law.

1 Installation

DANGER!

Before servicing any breaker, make sure that it matches the breaker discussed. If the breaker does not match the breaker described above, please call CBS ArcSafe® for more information.


ATTENTION!

The location of certain items such as mimic bus, stickers, and/or placards may interfere with the proper installation of the RSA. Please remove or reposition these items before installing the RSA.

1. Ensure that the switch is free from obstructions that may interfere with proper installation of the RSA




2. Position the RSA on the breaker, ensuring that locator on the RSA aligns with the lower lockout hole on the switch housing. Use the reference plate positioned beneath the locator to assist in aligning the RSA.



3. Ensure the magnets are fully seated against the breaker door and then turn the handles of the twist-lock magnets 180° to lock the RSA in place.

4. Pull the actuator arm upward, and tilt the arm at a slight angle so it can be inserted into the receptacle on the switching mechanism, then insert it into the switching receptacle.
5. After installing the actuator arm, ensure that the spacing between the shaft collar and bearing block on the actuator arm is between 1.75 and 2 inches apart. This distance ensures proper spring tension to prevent the arm from disengaging the switch mechanism during operation.



The RSA is now ready for operation.

2 Operation

ATTENTION!

Please ensure that all cables are clear of moving parts. Failure to do so may result in damage to cables and/or actuator.

ATTENTION!

Please ensure that the batteries to the RSO-I AR are fully charged or that the unit is plugged into AC power.

For detailed instructions on the operation of the RSO-I AR please see the RSO-I AR Manual.

1. Ensure that the RSA is properly installed. See the Installation section for detailed instructions.
2. Plug the RSO-I AR into the motor control box.
3. Exit the arc flash boundary
4. Turn the power switch on the RSO-I AR to the ON position.
5. Ensure that the Auto Retract (AR) function is OFF
6. Press and hold CLOSE to turn ON the switch.
7. Press and hold TRIP to turn OFF the switch.




3 Adjustments

The RSA comes adjusted from the factory to fit most common configurations, and should not need to be adjusted in most cases. However, if adjustments do need to be performed, it is recommended that they be done on de-energized and isolated equipment to prevent possible damage or injury.


3.1 Travel Adjustment

The RSA has travel stops on it to prevent over-travel and damage of the handle operator during operation.


1. Install the RSA as directed in the Installation section
2. Loosen the two lock screws on the travel stops.



3. To set the lower travel limit for the RSA, manually rotate or tap the RSO CLOSE button to carefully actuate the RSA until the breaker has reached the CLOSED position. Rotate the outer travel stop until a slight click is heard from the outer stop switch, and re-tighten the lock screw.



4. To set upper travel limit for the RSA, manually rotate or tap the RSO TRIP button to carefully actuate the RSA until the Handle Operator is at the OPEN position. Rotate the inner travel stop until a slight click is heard from the inner stop switch, and re-tighten the lock screw.







3.2 Depth Adjustment

The mounting depth of the RSA can be adjusted to avoid interference with bolts, plackards, and other items mounted to the switchgear door. To adjust the depth of the RSA, both the Magnets and the Locator must be adjusted at the same time, to the same level.

3.2.1 Magnet Depth

1. Loosen the two bolts on each magnet, as shown below.




2. Install the RSA as described in the Installation section.
3. Slide each magnet up or down as required to accommodate any obstructions on the gear door.
4. Re-tighten any loosened bolts.

3.2.2 Locator Position

1. Loosen the two bolts on the locator, as shown below.



2. Install the RSA as described in the Installation section.
3. Slide the locator as required to position it properly on the switch.



4. Re-tighten any loosened bolts.



Distance Is Safety[®]

A Group CBS Company

RSA-117B
Installation and Operation

2616 Sirius Road
Denton, TX 76208
Tel: 877-4-SAFETY
Fax: 940-382-9435
Website: www.CBSArcSafe.com
Email: info@CBSArcSafe.com

DANGER!

Ensure that personnel using this equipment are adequately trained in the operation of the switchgear they are planning to work with; that they are correctly stationed outside the arc flash boundary; and that they comply with all applicable Federal, State, Local, and In-house safety regulations and procedures. Attention should be given to distance, angle, and personal protective equipment (PPE).